

# HVAC Subcommittee Meeting #4



**AYAD AL-SHAIKH**  
**MARK MODERA**  
**MAY 2018**

# Agenda

2

- Discuss Measure Summary Template
  - **Question**: What changes should we make before you see your first example? (*Requested feedback by Friday, 6/8/18*)
- Q2 HVAC Measure review

Blue text = Changing and first time that item is mentioned  
*Italics* text = Item that has not been completed

# Parallel Path Approach – eTRM / HVAC

3

Q2'18

Q3'18

Q4'18

Q1'19

Q2'19

## Path 1: HVAC Measure Consolidation

- Create structure
- Consolidate 50+ HVAC Measures
- Affirmation of 50+ HVAC Measure for eTRM

## Path 2: HVAC Measure Analysis and Evolution

- Stakeholder Feedback on Measure Summary Template
- Complete 50+ Measures Summaries
  - HVAC Modelling Charette
- Feedback on existing Measures
- Sensitivity analyses
  - Prototype comparison
- Develop & validate/compare modelling approach

Questions at end...

# Questions that Subcommittee Members Will Be Asked...

4

- Do Cal TF Subcommittee Members agree with savings?
- Are the base case models reasonable at predicting actual load
  - ❑ Should schedules be different
  - ❑ Are internal loads what they think they would be for this building prototype
  - ❑ Are the measures being modeled correctly? (Different EER value or change run time variables)
  - ❑ Input on most sensitive parameters for measure (e.g. infiltration, hours of operation, LPD, etc.)
  - ❑ How are we documenting base and measure case for these measures (for example, why is base case efficiency whatever it is? Is saying it is Title 24 enough)?
  - ❑ Are there additional degradation factors built in to the model?
- What other questions should we be asking or planning for?

*Disclaimer – CA Building Prototype models are likely to change through the DEER2020 Update*

# Review “Measure Summary Template”



5

# HVAC Measure List – for Q2 Consolidation

6

- *Draft HVAC Measure List for Q2*
  - ❑ 5.05 Water-Cooled Chillers
  - ❑ 5.39 Air-Cooled Packaged Chiller
  - ❑ 5.09 Res DuctTestSeal
  - ❑ 5.17 Whole House Fan
  - ❑ 5.18 High Efficiency Furnaces - Residential
  - ❑ 5.22 Variable Refrigerant Flow - Commercial
    - ✦ Heat Pump & Heat Recovery Systems >65kBtu/h
  - ❑ 5.24 Unitary Air-Cooled - Commercial
    - ✦ Air Conditioners and Heat Pump >=65 kBtu/h
  - ❑ 5.25 Unitary Air Cooled - Commercial
    - ✦ Air Conditioners and Heat Pump Units Under 65 kBtu/h
  - ❑ 5.27 High Efficiency Package Terminal AC and Heat Pump
    - ✦ 24kBtu/h (2 tons) and under
  - ❑ 5.40 Upstream Residential HVAC
  
  - ❑ 5.51 Water Source Heat Pumps
  - ❑ 5.03 Space Heating Boilers

# Measure Consensus -

## 5.05 – Water Cooled Chillers

7

### ● Offering

#### □ SCE workpaper ([SCE17HC043.0](#))

##### ✦ Variable speed centrifugal chiller

###### ○ 5 capacity sizes:

- <150 tons, (added)
- ≥150 to <300 tons,
- ~~≥300 to <600 tons~~, [≥300 to <400 tons, ≥400 to <600 tons, \(split\)](#)
- ≥600 tons

###### ○ ~~2 efficiency tiers~~ [Path A and Path B \(10% improvement of kW/ton and IPLV\)](#)

##### ✦ ~~Constant speed centrifugal chiller~~

##### ✦ ~~Constant speed screw / scroll chillers~~

##### ✦ Variable speed screw chiller

###### ○ 5 capacity sizes:

- <75 tons,
- ≥75 to <150 tons,
- ≥150 to <300 tons,
- ≥300 to <600 tons, (split)
- ≥600 tons

###### ○ Path A and Path B (10% improvement of kW/ton and IPLV)

Blue text = Changing and first time that item is mentioned  
*Italics text* = Item that has not been completed

# Measure Consensus -

## 5.05 – Water Cooled Chillers

8

### ● Offering

- ❑ Savings use a weighted average approach for building type and select Climate Zones are chosen for savings, which matches the lighting approach.

Program Type	HVAC Vintage	Building Type	PA	Climate Zone
ROB	Ex	Com	SCE	CZ06, CZ08, CZ09, CZ10, CZ13, CZ14, CZ15, CZ16
			PGE	CZ01, CZ02, CZ03, CZ04, CZ05, CZ11, CZ12
			SDG	CZ07

- ❑ Savings come directly from DEER.
- ❑ **Question:** Recommend moving CZ13 to the PG&E value based upon weighted area (or does this weighting reflect a larger percentage of claims from SCE/CZ13?).

Ref No	Name	PGE	SCE	SCG	SDGE
5.05	Water-Cooled Chillers		1,071,870		

- ❑ HVAC Types: cWtd
- ❑ Delivery: Upstream / **Midstream**; ROB
- ❑ Climate Zones: Includes all climate zones

Blue text = Changing and first time that item is mentioned  
*Italics text* = Item that has not been completed



# Measure Consensus -

## 5.05 – Water Cooled Chillers

9

### • Stage 1 Issues

#### □ Programs offer incentives in both Path A and Path B

- ✦ Exceed Path A requirements for full-load and integrated part-load efficiency
- ✦ Exceed Path B requirements for full-load and integrated part-load efficiency

*TABLE 110.2-D WATER CHILLING PACKAGES – MINIMUM EFFICIENCY REQUIREMENTS*

Equipment Type	Size Category	Path A Efficiency <sup>a,b</sup>	Path B Efficiency <sup>a,b</sup>		
Water Cooled, Electrically Operated Positive Displacement	< 75 Tons	≤ 0.750 kW/ton ≤ 0.600 IPLV	≤ 0.780 kW/ton ≤ 0.500 IPLV		
	≥ 75 tons and < 150 tons	≤ 0.720 kW/ton ≤ 0.560 IPLV	≤ 0.750 kW/ton ≤ 0.490 IPLV	≤ 0.610 kW/ton ≤ 0.550 IPLV	≤ 0.695 kW/ton ≤ 0.440 IPLV
	≥ 150 tons and < 300 tons	≤ 0.660 kW/ton ≤ 0.540 IPLV	≤ 0.680 kW/ton ≤ 0.440 IPLV	≤ 0.610 kW/ton ≤ 0.550 IPLV	≤ 0.635 kW/ton ≤ 0.400 IPLV
	≥ 300 Tons and < 600 tons	≤ 0.610 kW/ton ≤ 0.520 IPLV	≤ 0.625 kW/ton ≤ 0.410 IPLV	≤ 0.560 kW/ton ≤ 0.520 IPLV	≤ 0.595 kW/ton ≤ 0.390 IPLV
	≥ 600 tons	≤ 0.560 kW/ton ≤ 0.500 IPLV	≤ 0.585 kW/ton ≤ 0.380 IPLV	≤ 0.560 kW/ton ≤ 0.500 IPLV	≤ 0.585 kW/ton ≤ 0.380 IPLV
			≥ 600 tons	≤ 0.560 kW/ton ≤ 0.500 IPLV	≤ 0.585 kW/ton ≤ 0.380 IPLV

### • Savings Methodology

#### □ Direct from DEER

Blue text = Changing and first time that item is mentioned  
*Italics text* = Item that has not been completed

# Measure Consensus -

## 5.39 – Air Cooled Chiller

10

### ● Offering

- ❑ Workpaper (PGECOAPP1200 R7, SCE17HC030.1)
- ❑ Base = Code / Path A
  - ✦ Air-Cooled Constant Speed Screw Chillers, for use in non-residential buildings, meeting the 2016 California Title 24 minimum efficiency standards in both full load (EER) AND part load conditions (IPLV)
- ❑ Measure
  - ✦ Tier 1 – 10% Improvement (EER and IPLV)
  - ✦ Tier 2 – 20% Improvement (EER and IPLV)
  - ✦ 2 capacity bins: <150 tons and >=150 tons
  - ✦ **Question**: Note that this measure excludes Title 24 “Path B” chillers ; limit technology meets the Tier 2 standard currently.
- ❑ Delivery: Upstream and Midstream; ROB
- ❑ Climate Zones: 1-16

# Measure Consensus -

## 5.39 – Air Cooled Chiller

### ● Offering

- ❑ **Question:** Any insights from Impact Evaluation 2015 (Upstream HVAC program)
- ❑ Savings use a weighted average approach for building type and select Climate Zones are chosen for savings, which matches the lighting approach.

Program Type	HVAC Vintage	Building Type	PA	Climate Zone
ROB	Ex	Com	SCE	CZ06, CZ08, CZ09, CZ10, CZ13, CZ14, CZ15, CZ16
			PGE	CZ01, CZ02, CZ03, CZ04, CZ05, CZ11, CZ12
			SDG	CZ07

- ❑ Savings come directly from DEER.
- ❑ **Question:** Recommend moving CZ13 to the PG&E value based upon weighted area.
  - ✦ FYI – no claims in 2017 (Q1-Q3) in CZ13 for either PG&E or SCE
  - ✦ Claim in other climate zones (PG&E - ~100,000 kWh; SCE - ~1,500,000 kWh)

Ref No	Name	PGE	SCE	SCG	SDGE
5.39	Air-Cooled Packaged Chiller	100,295	1,516,405		

# Measure Consensus -

## 5.09 – Duct Test & Seal, Residential

### ● Offering

- ❑ Workpaper (PGE3PHVC159, R4)
- ❑ High Duct Leakage:
  - ✦ Base case description for High Duct Leakage:
    - 40% (20% Supply/20% Return) Leakage (single- and multi-family)
    - 35% Supply Leakage (mobile home)
  - ✦ Measure case description for High Duct Leakage Reduction:
    - Residential: Duct Sealing (Total Leakage Reduced from High (35/40%) to Low (15/12%)
    - (35% to 15% for mobile home and 40% to 12% for single- and multi- family)
- ❑ Medium Duct Leakage:
  - ✦ Base case description for Medium Duct Leakage:
    - 24% (12% Supply/12% Return) Leakage (single- and multi-family)
    - 25% Supply Leakage (mobile home)
  - ✦ Measure case description for Medium Duct Leakage Reduction:
    - Residential: Duct Sealing (Total Leakage Reduced from High (25/24%) to Low (15/12%)
    - (25% to 15% for mobile home and 24% to 12% for single- and multi- family)
- ❑ Building Types
  - ✦ Res: MFm, DMO, SFm
- ❑ HVAC Types
  - ✦ rDXGF
- ❑ Delivery: Upstream; RC (Retro-commissioning)
- ❑ Climate Zones: 1-5, 11-13, 16 (PG&E)

Blue text = Changing and first time that item is mentioned  
*Italics text* = Item that has not been completed

# Measure Consensus -

## 5.09 – Duct Test & Seal, Residential

13

### ● Stage 1 Issues

#### □ Offering:

- ✦ Climate zones seem to be limited to PG&E territory

### ● Savings Methodology

#### □ DEER values

Measure Name	Impact ID
Residential: Duct Sealing (Total Leakage Reduced from (40/35%) to (12/15%))	Res-DuctSeal-HighToLow-wtd
Residential: Duct Sealing (Total Leakage Reduced from (25/24%) to (15/12%))	Res-DuctSeal-MedToLow-wtd

#### □ Normalized units

- ✦ **Question:** Translated from “Cap-Tons” to “per Household”
  - Should we revert back to using “Cap-Tons”?
- ✦ “Capacity values per Household” comes from EnergyImpacts\_RB-HV-MHDuctSeal-25pct-15pct; EnergyImpacts\_RB-HV-MFDuctSeal-40pct-12pct
  - Varies by BT and CZ (except DMO)

Ref No	Name	PGE	SCE	SCG	SDGE
5.09	Res DuctTestSeal	56,299		84,744	87,493

# Measure Consensus -

## 5.17 – Whole House Fan (WHF), Residential

14

### ● Offering (no claims in 2017, Q1-Q3)

- ❑ Workpaper (SCE13HC005.2, PGECO HVC134 R2) – SCE update in 2018
- ❑ Base case
  - ✦ Includes an HVAC system; however, does not include air-economizing
- ❑ Measure case
  - ✦ Requires that WHF be sized at least 2 cfm/sqft. of conditioned floor area
  - ✦ Have at least 1 sqft. of attic vent free area for each 375 cfm of rated WHF air flow
  - ✦ May include a control timer (e.g., 30 min. WHF operation) and/or a two speed controller (e.g., low fan speed and high fan speed).
- ❑ Building Types
  - ✦ Res: MFm, DMO, SFm
- ❑ HVAC Types
  - ✦ rDXGF
- ❑ Delivery: DI and Downstream; REA (Retrofit Add-On)
- ❑ Climate Zones: 6, 8, 9, 10, 13 – 16 (SCE)

Blue text = Changing and first time that item is mentioned  
*Italics text* = Item that has not been completed

# Measure Consensus -

## 5.17 – Whole House Fan (WHF), Residential

### • Stage 1 Issues

#### □ Offering:

- ✦ Climate zones seem to be limited to SCE territory
- ✦ Older version of PG&E workpaper can extend climate zones

### • Savings Methodology

Measure Name	Impact ID
Whole house fan	D03-441

#### □ Normalized units

- ✦ Translated from “1000 sqft” (measure area) to “per Household”
- ✦ Translation based upon prototype buildings (per BT and CZ). Example:

Climate Zone	Bldg. Type	Bldg. Vintage	Bldg. HVAC	Square Feet/Home	Num. Unit
6	DMo	Ex	rWtd	1,220	1.22
6	MFm	Ex	rWtd	1,000	1.00
6	SFm	Ex	rWtd	1,710	1.71

Blue text = Changing and first time that item is mentioned  
*Italics text* = Item that has not been completed

# Measure Consensus -

## 5.18 – High Efficiency Furnaces

### ● Offering

- ❑ Workpaper (PGECOHC145 R3, PGECOHC147 R3, WPSCGREHC130115A-Rev04)
- ❑ Common Offerings
  - ✦ Res-GasFurnace-AFUE95 (AFUE  $\geq$  95% & < 96%)
  - ✦ Res-GasFurnace-AFUE97 (AFUE  $\geq$  97%)
- ❑ PG&E Specific Offerings
  - ✦ Furnace with variable speed motor (VFD or ECM), only CZ11, 12, 13
- ❑ SCG Specific Offerings
  - ✦ Res-GasFurnace-AFUE92 (AFUE  $\geq$  92% & < 95%)
  - ✦ Res-GasFurnace-AFUE96 (AFUE  $\geq$  96% & < 97%)
- ❑ Building Types
  - ✦ Res: MFm, DMO, SFm
- ❑ HVAC Types
  - ✦ rWtd
- ❑ Delivery: DI and Downstream; ROB (PG&E) / ROBNC (SCG)
- ❑ Climate Zones: 1-16, IOU



# Measure Consensus -

## 5.18 – High Efficiency Furnaces

- Stage 1 Issues

- Offering:

- ✦ Question: SCG uses additional tiers
    - ✦ Question: PG&E offers variable speed fan addition

- Savings Methodology

Measure Name	Impact ID
High efficiency furnace	Res-Furnace-dHIR

- Normalized units

- ✦ Translated from “cap-kBTUh” to “per Household”

- Motor calculations

- ✦ Based upon scaled values from a disposition from a high efficiency blower motor workpaper (PGECHVC139)
    - ✦ Calculates kWh, kW, and negative gas impact

# Measure Consensus -

## 5.18 – High Efficiency Furnaces

18

### • Stage 1 Issues

#### □ Offering:

- ✦ SCG uses additional tiers

<i>(source 2017, Q1-Q3 IOU Claims Data)</i>		Gross Therms			
Ref No	Name	PGE	SCE	SCG	SDGE
5.18	High Efficiency Furnaces - Residential			11,196	542

SCG	PG&E	Measure Description	Number of Units	Gross Therms
540357		Central Gas Furnace 92% AFUE	7	169
540358	x	Central Gas Furnace 95% AFUE	237	6,338
530641		Central Gas Furnace 96% AFUE	85	2,805
530642	x	Central Gas Furnace 97% AFUE	54	1,885

#### □ Notes

- ✦ Not a large savings measures
- ✦ More savings could be claimed with additional offerings (like SCG), but equivalent of about 6% increase.

# Measure Consensus -

## 5.24 – Unitary Air-Cooled A/C $\geq 65$ kBTU/hr

19

### ● Offering

- ❑ Workpaper (PGECOHC128 R9, SCE17HC035.0)
- ❑ Base case = Code
  - ✦ Standard Efficient EER/IEER Rated Packaged/Split Air Conditioner, 65kBtu/h or larger
- ❑ Measure case
  - ✦ High Efficient EER/IEER Rated Packaged/Split Air Conditioner, 65kBtu/h or larger
  - ✦ Split-package or Single-package units
  - ✦ Like for like; within 5% of existing capacity
- ❑ Capacity Ranges / Efficiency Tiers
  - ✦  $\geq 5.4$  to  $< 11.3$  tons; 4 tiers plus to-code offering
  - ✦  $\geq 11.3$  to  $< 20$  tons; 3 tiers plus to-code offering
  - ✦  $\geq 20$  to  $< 63.3$  tons; 3 tiers plus to-code offering
  - ✦  $\geq 63.3$  tons; 3 tiers plus to-code offering
- ❑ Building Types
  - ✦ Com (weighted average commercial building type)
- ❑ HVAC Types
  - ✦ cDXGF
- ❑ Delivery: Upstream / Midstream; ROB and NC (PG&E)
- ❑ Climate Zones: 1-16, IOU

<i>(source 2017, Q1-Q3 IOU Claims Data)</i>		Gross kWh			
Ref No	Name	PGE	SCE	SCG	SDGE
5.24	Unitary Air-Cooled Commercial Air Conditioners and Heat Pumps $\geq 65$ kBtu/h	1,736,774	322,188		1,833


# Measure Consensus -

## 5.24 – Unitary Air-Cooled A/C ≥65 kBTU/hr

20

### • Savings Methodology

- ❑ DEER savings are used directly
  - ✦ **Question:** Simplified approach (only using one package unit savings / one CZ to get profile)
  - ✦ Why is the weighted average building type savings used? Claims data still reports BT, so difference can be calculated.
- ❑ Weighted value – claims quantity (dotted red line) is very similar to COM value



# Measure Consensus -

## 5.25 – Unitary Air-Cooled A/C <65 kBTU/hr

21

### • Offering

- ❑ Workpaper (PGECOHC126 R7, SCE17HC012.0, WPSDGENRHC0023 R1)
- ❑ Base case = Code
  - ✦ Air cooled air conditioning or heat pump units with cooling capacities less than 65 kBTuh, for use in non-residential buildings, meeting the federal minimum efficiency standard of 14 SEER.
- ❑ Measure case
  - ✦ Air cooled air conditioning or heat pump units with cooling capacities less than 65 kBTuh, for use in non-residential buildings, meeting the minimum efficiency requirements
  - ✦ Packaged A/C, Split System A/C, Packaged HP, Split System HP
  - ✦ Like for like; within 5% of existing capacity
- ❑ Capacity Ranges / Efficiency Tiers
  - ✦ Packaged Air Conditioner
    - <55 kBTUh; 4 tiers plus to-code offering
    - 55 to <65 kBTUh; 4 tiers plus to-code offering
  - ✦ Split System Air Conditioner
    - <45 kBTUh; 4 tiers plus to-code offering
    - 45 to <55 kBTUh; 4 tiers plus to-code offering
    - 55 to <65 kBTUh; 4 tiers plus to-code offering
  - ✦ Packaged Heat Pump
    - <55 kBTUh; 4 tiers plus to-code offering
    - 55 to <65 kBTUh; 4 tiers plus to-code offering
  - ✦ Split System Heat Pump
    - <55 kBTUh; 4 tiers plus to-code offering
    - 55 to <65 kBTUh; 4 tiers plus to-code offering
- ❑ Building Types
  - ✦ Com (weighted average commercial building type)
- ❑ HVAC Types
  - ✦ cDXGF
- ❑ Delivery: Upstream / Midstream; ROB and NC (PG&E)
- ❑ Climate Zones: 1-16, IOU

**Table 2: Minimum Efficiency Requirements**

	Program Tier	Minimum SEER	Minimum EER
Packaged Air Conditioner	Code	14.0	11.6
	Tier 1	15.0	12.0
	Tier 2	16.0	12.4
	Tier 3	17.0	13.0
	Tier 4	18.0	14.0
Split System Air Conditioner	Code	14.0	12.0
	Tier 1	15.0	12.5
	Tier 2	16.0	13.0
	Tier 3	17.0	13.5
	Tier 4	18.0	14.0
Packaged Air Cooled Heat Pump	Code	14.0	11.6
	Tier 1	15.0	12.0
	Tier 2	16.0	12.4
	Tier 3	17.0	13.0
	Tier 4	18.0	14.0
Split System Air Cooled Heat Pump	Code	14.0	12.0
	Tier 1	15.0	12.5
	Tier 2	16.0	13.0
	Tier 3	17.0	13.5
	Tier 4	18.0	14.0

(source 2017, Q1-Q3 IOU Claims Data)		Gross kWh			
Ref No	Name	PGE	SCE	SCG	SDGE
5.25	Unitary Air Cooled Commercial Air Conditioning and Heat Pump Units Under 65 kBTuh	856,208	395,891		54,665

6/13/2018

# Measure Consensus -

## 5.25 – Unitary Air-Cooled A/C <65 kBTU/hr

22

### ● Savings Methodology

- ❑ DEER savings are used directly
- ❑ “To-Code” savings are calculated as follows:

#### To Code Savings Portion Measures

The To Code Savings Portion measures in this work paper are the savings from retrofitting customer existing equipment (various SEER values) to 14 SEER code-compliant equipment. The savings were determined by subtracting the “AStdWB” savings from the “APreWB” savings for 15 SEER ACs and HPs. The result was the difference between customer existing equipment and 14 SEER equipment. Measures savings (ROB, NEW) are attributed to the Upstream and Midstream HVAC programs.

Example: <55kBtuh To Code Savings Portion Packaged Air Conditioner, SCE, Assembly, CZ 06

DEER savings:

EnergyImpactID	APreWBkWh	APreWBkW	APreWBtherm	AStdWBkWh	AStdWBkW	AStdWBtherm
NE-HVAC-airAC-Pkg-lt55kBtuh-15p0seer	560	0.293	-3.12	129	0.0454	-1.2

kWh Savings = 560 - 129 = **431 kWh**

kW Reduction = 0.293 - 0.0454 = **0.2476 kW**

therm Savings = -3.12 - (-1.2) = **-1.92 therms**

Blue text = Changing and first time that item is mentioned  
*Italics text* = Item that has not been completed

# Measure Consensus -

## 5.27 – High Efficiency PTAC and HP (<2 tons)

23

### ● Offering

- ❑ Workpaper (PGE COHVC114 R5, SCE17HC007.0, WPSDGENRHC1052 R0)
- ❑ Base = Code
  - ✦ Package terminal air conditioning units (PTAC) or package terminal heat pumps (PTHP) that are through the wall, self-contained and less than or equal to 2 tons ( $\leq 24\text{kBtu/h}$ )
- ❑ Measure = 20% Higher than Code
  - ✦ Ductless mini-split A/C do not apply

### ❑ Building Types

- ✦ SDG&E – no residential

DEER Building Type used for Measure Savings	Work Paper Building Type
Lodging – Hotel	Agricultural
	Health/Medical - Nursing Home
	Health/Medical - Clinic
	Lodging - Hotel
	Lodging - Guest Rooms
	Manufacturing - Bio/Tech
	Manufacturing - Light Industrial
	Industrial
	Office - Large
	Office - Small
	Restaurant - Fast-Food
	Retail - Small
	Warehouse - Refrigerated
Lodging - Motel	Residential Multi-family (Dwelling)
	Lodging - Motel
	Residential Multi-family (Common)
	Residential Single Family

Installation Type	Unit Capacity	T24 Minimum EER (AC)	T24 Minimum EER (HP)	Measure Minimum EER (AC)	Measure Minimum EER (HP)
ROB	$\leq 7,000$ Btu/hr	9.41	9.31	11.29	11.17
	$> 7,000$ and $\leq 15,000$ Btu/hr	8.56	8.46	10.27	10.15
	$> 15,000$ Btu/hr	7.71	7.61	9.25	9.13
NEW	$\leq 7,000$ Btu/hr	11.9	11.9	14.28	14.28
	$> 7,000$ and $\leq 15,000$ Btu/hr	10.7	10.7	12.84	12.84
	$> 15,000$ Btu/hr	9.5	9.5	11.4	11.4

### ❑ Delivery: Downstream; ROB, NC

- ✦ **Question:** PG&E/SDG&E = ROB only

### ❑ Climate Zones: 1-16, IOU

# Measure Consensus -

## 5.27 – High Efficiency PTAC and HP (<2 tons)

24

### ● Offering

□ Norm Unit: Cap-Tons

□ HVAC Types

✦ dxAC, dxHP

✦ **Question:** Does this breakdown seem reasonable/accurate?

□ Energy Savings – from DEER

✦ DEER provided data for the following unit capacity ranges for PTAC and PTHP units:

- <7 kBtuh
- 7-15 kBtuh
- >15 kBtuh

✦ **Question:** Which is the preferable approach?

- PG&E: These ranges were combined, via a **weighted average**, into one <=24kBtuh range for PTAC units and one <=24kBtuh range for PTHP units per the following table.
- SCE: Savings for this work paper are based on **7-15 kBtuh capacity range**, since nearly all of the previous participation falls under this range
- SDG&E: Uses savings that align with each bin (2 types and 3 capacity ranges)

Unit Capacity Ranges	% of Units Installed
PTAC/PTHP <7kBtuh	5%
PTAC/PTHP 7-15kBtuh	90%
PTAC/PTHP >15kBtuh	5%

(source 2017, Q1-Q3 IOU Claims Data)		Gross kWh			
Ref No	Name	PGE	SCE	SCG	SDGE
5.27	High Efficiency Package Terminal Air Conditioners & Heat Pumps 24kBtu/h (2 tons) and under		232,306		



# Measure Consensus -

## 5.40 – Upstream HVAC, Residential

25

### ● Offering

#### ❑ Workpaper (PGECOHC166 R3, SCE13HC062.1)

Tier 2					
	Air Conditioners		Heat Pumps		Gas Furnaces
	Split System	Packaged	Split Air Source	Packaged	AFUE
Efficiency	17 SEER, 13 EER	15 SEER, 12 EER	17 SEER, 13 EER, 9 HSPF	15 SEER, 12 EER, 8 HSPF	96% AFUE gas and propane furnaces, gas and propane boilers, oil furnaces and hot water boilers

Tier 3					
	Air Conditioners		Heat Pumps		Gas Furnaces
	Split System	Packaged	Split Air Source	Packaged	AFUE
Efficiency	18 SEER, 13 EER	16 SEER, 12 EER	18 SEER, 13 EER, 9 HSPF	16 SEER, 12 EER, 9 HSPF	97% AFUE gas and propane furnaces, gas and propane boilers, oil furnaces and hot water boilers

- ❑ Building Types: Residential
- ❑ Delivery: Upstream; ROB
- ❑ Climate Zones: 1-16, IOU

# Questions...

26

- Next meeting planned for June 14<sup>th</sup> (Thursday)
- Focus on finalizing questions related to Q2 Measures
- Request feedback regarding Measure Summary Template by June 8<sup>th</sup>.

# Back-up...

27


# HVAC Electric Savings

(Source – 2017 Q1-Q3, IOU Claims Data)

28

## HVAC - Electric Savings by Measure

(Source - 2017 Q1-Q3 IOU Deemed Claims)




# HVAC Electric Savings

(Source – 2017 Q1-Q3, IOU Claims Data)

29

## HVAC - Electric Savings by Measure

(Source - 2017 Q1-Q3 IOU Deemed Claims)



Ref No	Name	Gross kWh	PGE	SCE	SDGE
5.45	Guest Room PTAC/PTHP Energy Management System	7,626,835	7,599,985		
5.13	Efficient Fan Controller for Residential Air Conditioners	4,940,741	2,474,047	2,394,509	72,185
5.10	Residential HVAC Quality Maintenance and Motor Retrofit	4,044,713	3,661,735	204,453	178,525
5.52	Whole House - Residential	3,460,215	290,621	3,169,595	
5.41	Variable Speed Drive on HVAC Fan Control	3,332,090	2,223,110	1,108,980	
5.49	Enhanced Ventilation for Packaged HVAC Units with Gas Heating and Packaged Heat Pumps	3,232,393	1,740,763	1,422,159	
5.15	Unoccupied Supply Fan Control	3,038,106	2,113,409	924,697	
5.02	Economizer Repair	2,704,019	679,997	2,024,022	
5.14	VFD Retrofit to Central Plant Systems	2,484,678		2,484,678	
5.24	Unitary Air-Cooled Commercial Air Conditioners and Heat Pumps >=65 kBtu/h	2,060,795	1,736,774	322,188	1,833
5.32	Commercial Condenser Coil Cleaning	2,039,439	66,164	490,331	1,482,943
5.42	Brushless Fan Motor for Residential Central AC	1,638,174		1,638,174	
5.39	Air-Cooled Packaged Chiller	1,616,700	100,295	1,516,405	
5.30	Refrigerant Charge	1,433,067	164,420	732,081	536,566
5.25	Unitary Air Cooled Commercial Air Conditioning and Heat Pump Units Under 65 kBtu/h	1,306,765	856,208	395,891	54,665
5.46	Programmable Communicating Thermostat for Demand Response	1,233,427	1,218,918		14,508
5.05	Water-Cooled Chillers	1,071,870		1,071,870	

*Includes measures with at least 1M kWh; 18 more measures with savings not shown.*


# HVAC Gas Savings

(Source – 2017 Q1-Q3, IOU Claims Data)

30

## HVAC - Gas Savings by Measure

(Source - 2017 Q1-Q3 IOU Deemed Claims)  
(negative gas from lighting removed, -4.2MTh)




Note: “DEER Measures”, which includes some HVAC measures, was removed since it is only a small part (SDG&E – Refrig Charge Adjustment, VAV Box).

# HVAC Gas Savings

(Source – 2017 Q1-Q3, IOU Claims Data)

31

**HVAC - Gas Savings by Measure**  
 (Source - 2017 Q1-Q3 IOU Deemed Claims)  
 (negative gas from lighting removed, -4.2MTh)



Ref No	Name	Gross Therms	PGE	SCE	SCG	SDGE
5.03	Space Heating Boilers	203,869	131,218		72,651	
5.46	Programmable Communicating Thermostat for Demand Response	177,985	174,913			3,072
5.49	Enhanced Ventilation for Packaged HVAC Units with Gas Heating and Packaged Heat Pumps	161,068	156,723	1,311		
5.06	Demand Controlled Ventilation for Single Zone Packaged HVAC	139,559	130,290	9,269		
5.15	Unoccupied Supply Fan Control	138,272	124,211	14,061		
5.52	Whole House - Residential	101,711	34,536	67,175		
5.47	Smart Thermostat	91,797	63,393		17,719	10,685
5.43	Multifamily Domestic Hot Water Temperature Reset Controller	55,749			55,749	
5.09	Res DuctTestSeal	14,603	6,052		4,321	4,230
5.02	Economizer Repair	12,644	9,122	3,522		
5.18	High Efficiency Furnaces - Residential	11,737			11,196	542
5.40	Upstream Residential HVAC	1,587	1,587			
5.19	High Efficiency Furnaces-Com	1,583	1,583			
5.11	Quality Installation for Residential Split Systems	1,027		1,027		
5.20	Gravity Wall Furnaces in Single-Family and Multi-Family Homes	252			252	
5.22	Variable Refrigerant Flow Commercial Heat Pumps & Heat Recovery Systems >65kBtu/h	14	14			

Note: “DEER Measures”, which includes some HVAC measures, was removed since it is only a small part (SDG&E – Refrig Charge Adjustment, VAV Box).  
 Eight (8) measures with negative gas savings, not shown.

# HVAC “Types”: DEER Measure

32

- Step 1: From READi, download a Measure ID and savings
- Step 2: Reproduce savings for a few test cases (if you have correct version of MASControl, possible to reproduce)
- Step 3: Using MASControl, generate base case and measure case for all applicable permutations (Building Type, Climate zone)
  - Vintage and HVAC Type may be required
  - Save as documentation in eTRM
- Step 4: Identify key differences between base and measure case (HVAC measure and other parameters)
- Step 5: Prepare “Measure Summary” template
- Step 6: Seek subcommittee feedback (for Stage II) on Measure Summary template
  - “Correctness” of base and measure case
  - Identified sensitive parameters (perhaps this is area for more EM&V)
- Step 7: Review OpenStudio measures to see if measure could be re-run in EnergyPlus to compare with DOE 2.2/eQUEST results.



# HVAC “Types”: “Roots” Within DEER Measure

33

- Step 1: From READi, download a Measure ID and savings
- Step 2: Locate building simulation models (from all utilities with WP) and results
  - Probably with utility WP developer consultant
- Step 3: Compare base case and measure case for all applicable permutations (Building, Climate zone)
  - Save as documentation in eTRM
  - Likely many fewer permutations because “typical” vintage and “typical” HVAC type used
- Step 4: Identify key differences between base and measure case for an individual utility (HVAC measure and other parameters) for each utility model.
- Step 5: Compare utility modeling approaches across utilities: 1. base case models and 2. measure case models
  - Identify key differences between utility base cases and utility measure cases
- Step 6: Complete “Measure Summary” template
- Step 7: Seek subcommittee feedback (for Stage II) on
  - “Correctness” of base and measure case
  - Different approaches taken by each utility
  - Which utility approach is best and run preferred models to fill in gaps throughout state
  - Identified sensitive parameters (perhaps this is area for more EM&V)
- Step 6: Review OpenStudio measures to see if measure could be re-run in EnergyPlus to compare with DOE 2.2/eQUEST results.

# HVAC Types: Non-DEER HVAC Measure

34

- Same approach as used for other non-HVAC measures, examples
  - Review RCT
  - Review savings calculation
  - Etc.